



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo No.: FSR/IND/WB/FES/20192020/79682

Date : 10-08-2026

From :
Divisional Fire Officer
North 24 Parganas Division,
West Bengal Fire & Emergency Services

To :
Starling International School
Bengal Roys Real Estate Private Limited, 457/29/1, Sondla Tank Road Bye Lane, P.O: Garulia, P.S: Noapara, Dist:
North 24 Parganas, Pin-743133

Sub : Renewal of Fire Safety Certificate for existing School building consisting G + II storied under principal group occupancy Educational in the name style "STARLING INTERNATIONAL SCHOOL" RUN BY : J D MEMORIAL EDUCATION TRUST at Bengal Roys Real Estate Private Limited, 457/29/1, Sondla Tank Road Bye Lane, P.O. and P.S:-Garulia, Noapara, Dist.-North 24 Parganas, Pin-743133

This is in reference to your AIN 211912606300012201 dated 07-Jul-2026 regarding Renewal of Fire Safety Certificate for existing School building consisting G + II storied under principal group occupancy Educational in the name style "STARLING INTERNATIONAL SCHOOL" RUN BY : J D MEMORIAL EDUCATION TRUST at Bengal Roys Real Estate Private Limited, 457/29/1, Sondla Tank Road Bye Lane, P.O. and P.S.-Garulia, Noapara, Dist.-North 24 Parganas, Pin-743133.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012201

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material conforming to the I.S. Specification.
3. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
5. Periodical flashing of water in the Hydrants Pipe line shall be made to maintain the efficiency working performance of the installed FFFS.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
7. The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the building and to operate in the event of Fire and Testing.
8. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer (if any) and switch gear room protection system to be maintained in proper manner & record keeping to be maintained in the fire prevention maintenance register.
10. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
11. Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
12. First-Aid Fire Fighting system shall be provided as per I.S. specification.
13. Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the building to keep them in perfectly good working condition at all the times.
14. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
15. The Fire Safety Audit & Electric Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
16. Standby pump must be installed as recommended.

This Fire Safety Certificate is valid for 3 (Three) year from the date of issue of this letter and have to be renewed within validity period & a certificate is to be obtained from the **Director General, West Bengal Fire & Emergency Services** for performance of all the Fire & Life Safety arrangement installations of the building.

Valid Upto : 08-Aug-2029



Signature valid

Digitally Signed.
Name: NIKHIL RANJAN ROY
Date: 10-Aug-2023 13:16:05
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012201